

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3230-1518:106 Page 1 of 1

**CATEGORY:** Leakage Rated Dampers

**LISTEE:** Prefco Products, Inc., 2823 Route 413, Buckingham, PA 18912  
Contact: Richard McNutt (215) 340-1707

**DESIGN:** Models 5000 leakage rated dampers. Refer to listee's data sheet for detailed product description and operational considerations. Models listed below:

<i>Models</i>	<i>Mounting Position</i>	<i>Rating</i>	<i>Width, In.</i>		<i>Height, In.</i>	
			<i>Min</i>	<i>Max</i>	<i>Min</i>	<i>Max</i>
5010, 5015, 5020, 5020-1, 5030, 5031, 5040, 5041	V	III-350	10	30	10	24
	V & H	III-250 III-450 IV-250 IV-450	6	36	5	45
	V	III-550	6	72	5	45
5010-G, 5015-G, 5020-G, 5020-1G, 5030-G, 5031-G, 5040-G, 5041-G, 5040-G, 5041-G,	V & H	I-350 I-450	10	30	10	24
	V	II-250	6	72	5	45

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, classification and UL label.

**APPROVAL:** Listed as leakage rated dampers for use in heating, ventilating and air conditioning duct systems passing through fire resistive walls and partitions.

**NOTE:** For fire rated classification, refer to CSFM Listing No. 3225-1518:100.

05-26-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 17, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager